

Website Updated:
 Active Construction List
 Updated:

Chemung County Stormwater
 Construction Inspection
 Erosion and Sediment Control



Project Name FedEx	Date 10-15-15
Location Holding Point Horseheads	Permit #NYR10Z781
Weather Conditions <i>Sunny</i>	Entry Time: <i>11:22</i>
On-Site Representative Present: Willy McCarthy	Exit Time: <i>11:47</i>

Construction Site Notes:

-site stripped of topsoil.
-stormwater features rough graded

Yes	No	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All erosion and sediment control measures installed/constructed
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	All erosion and sediment control measures maintained properly
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Are there currently more than 5 acres disturbed w/o prior approval
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Have stabilization measures been initiated in inactive areas
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Are permanent stormwater control measures being implemented
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Was there a discharge into the receiving water on the day of inspection
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Evidence of turbidity or oil in the receiving waters
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Are weekly inspections being performed?
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Are the inspections being performed by a qualified individual?

Corrections Needed:

-silt fence has holes in a number of areas along the perimeter.

Satisfactory Marginal Unsatisfactory

Date <i>10/15/15</i>	Inspector <i>Jessica Veringri</i>
----------------------	-----------------------------------



CHEMUNG
COUNTY
STORMWATER
COALITION

851 Chemung Street
Horseheads, New York 14845
Ph. 607.796.2216

PROJECT:	Fed Ex Ground Shipping Facility
	Village of Horseheads
	Munic. Construction Insp.
	October 15, 2015

BY	Jessica Verrigni, CPESC, CPSWQ
-----------	--------------------------------



Beginning of concrete washout area.



Holes in silt fence around entire site that require repair.



Topsoil pile has been seeded and is growing grass.



One of the stormwater basins rough graded.