

Website Updated:   
 Active Construction  
 List Updated

Chemung County Stormwater  
 Construction Inspection  
 Erosion and Sediment Control



Project Name Uhaul	Date 10-19-15
Location SR 14 HORSEHEADS NY	Permit # NYR 10Y916
Weather Conditions Sunny	Entry Time: 2:05
On-Site Representative Present: none	Exit Time: 2:15

Construction Site Notes:

-no work is being done at this time. Grading is complete but 80% vegetation not achieved.

Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
	X		All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
		X	Are permanent stormwater control measures being implemented
		X	Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
	X		Are weekly inspections being performed?
	X		Are the inspections being performed by a qualified individual?

Corrections Needed:

-silt fence needs replacement in a number of areas where equipment has graded over the top of it.

Satisfactory	Marginal <i>K.</i>	Unsatisfactory
Date 10/19/15	Inspector <i>Jessica Bernigni</i>	



851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

<b>PROJECT:</b>	UHaul grading project
	Town of Horseheads
	Municipal Const. Inspection
	October 19, 2015


<b>BY</b>	Jessica Verrigni, CPESC, CPSWQ
-----------	--------------------------------




Large areas are not 80% vegetated yet.



Large areas are not 80% vegetated yet.



Silt fence not maintained.



Silt fence not maintained.