



---

851 Chemung Street  
Horseheads, New York 14845

May 8, 2019

Thomas Whispel, Code Enforcement Officer  
Town of Big Flats  
476 Maple Street  
Big Flats, NY 14814

RE: Williams Toyota, Big Flats (T), Chemung (Co), NY

Mr. Whispel,

I have completed a cursory review of the Williams Toyota Erosion and Sediment Control Plan dated May 2019 and received May 7, 2019. Based upon my review of the above information, I believe the proposed erosion and sediment control plan is consistent with the Town of Big Flat's Stormwater Management and Erosion and Sediment Control Law. This acceptance only pertains to the grading and initial filling of the site. This acceptance is based on the following conditions.

1. Silt and/or sediment shall not be allowed to leave the project site, including tracking onto public streets. Erosion and sediment controls, outlined in the accepted Erosion & Sediment Control Plan, shall be implemented and maintained to ensure this purpose. If silt, sediment, and/or dust are found to be leaving the site, the Owner (or their contractor) shall take immediate actions to correct the situation.
2. One set of the Final Erosion and Sediment Control Plan must be on-site at all times during construction and site stabilization.

If you have any questions or comments regarding this letter, please do not hesitate to contact me.

Sincerely,

Jessica Verrigni, CPESC, CPSWQ

Cc- M. Maser, Maser Engineering  
JJ Carl, Chemung Stormwater Coalition