

851 Chemung Street  
Horseheads, New York 14845

June 11, 2020

Greg Larnard, Town of Horseheads Stormwater Management Officer  
Town of Horseheads  
150 Wygant Road  
Horseheads, NY 14845

RE: Dominion Energy LN-31 AC Mitigation Project


Mr. Larnard,

I have completed a review of the Dominion Energy LN-31 AC Mitigation Project Erosion and Sediment Control Plan dated May 2020 and received June 3, 2020. Based upon my review of the above information, I believe the proposed erosion and sediment control plan is consistent with the Town of Horsehead's Stormwater Management and Erosion and Sediment Control Law. This acceptance only pertains to work being done for the LN-31 Mitigation project. This acceptance is based on the following:

1. Silt and/or sediment shall not be allowed to leave the project site, including tracking onto public streets. Erosion and sediment controls, outlined in the accepted Erosion & Sediment Control Plan, shall be implemented and maintained to ensure this purpose. If silt, sediment, and/or dust are found to be leaving the site, the Owner (or their contractor) shall take immediate actions to correct the situation.
2. An electronic copy of the weekly Qualified Inspection report shall be emailed to the Town's Stormwater Management Officer and to the Chemung County Stormwater Coalition.
3. One set of the Final Erosion and Sediment Control Plan, stamped with the Stormwater Coalition's approval stamp, shall be on-site at all times during construction and site stabilization.
4. Prior to the start of construction, it is requested that the Applicant arrange a meeting with the Town's Code Enforcement, the Chemung County Stormwater Coalition, the Applicant's design professional and the Contractor to discuss requirements associated with the SWPPP and the SPDES Permit.

If you have any questions or comments regarding this letter, please do not hesitate to contact me.

Sincerely,

  
Jessica Verrigni, CPESC, CPSWQ

Cc- D. Fisher, Town Supervisor

J. Young, HDR  
K. Kratzer, Dominion Energy