

Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control

✓ updated  
active const.  
list.

Project Name	Hickory View	Date	7/2/12
Location	Hickory Grove Rd Big Flats	Permit #	
Weather Conditions	sunny	Entry Time:	
On-Site Representative Present:	Brian Robinson	Exit Time:	

Sketch of Project site-Include Disturbed Areas: 607-425-2169

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
X			All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	close
	X		Have stabilization measures been initiated in inactive areas	
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

\*

Comments: ① inspections need to be signed by qualified person  
② Keep eye on dust - not bad today  
③ 5 ac → cannot go over yet.

Satisfactory     
  Marginal     
  Unsatisfactory

Date 7/2/12      Inspector Jessica Derrugni



851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

**PROJECT:** Hickory View Apartments  
Municipal Construction Insp.  
July 2, 2012  
Town of Big Flats

**BY** Jessica Verrigni, CPESC, CPSWQ



Project road construction.



Contractor yard and soil stockpile. Contractor will be stabilizing the face of the stockpile.



Area being excavated for fill.



Active work area.