



851 Chemung Street
Horseheads, New York 14845

July 24, 2017

ATTN: Tom Whispel, Code Enforcement Officer/Stormwater Management Officer
Town of Big Flats
476 Maple Street
Big Flats, NY 14814

**RE: Updyke Residence
Owen Hollow Road
Erosion and Sediment Control Plan Acceptance**

Mr. Whispel,

I have completed a cursory review of the above-referenced project regarding the erosion and sediment control plan for the project. Based upon my review of the above information, I believe that the proposed erosion and sediment control plan is consistent with the Town of Big Flats' Stormwater Management and Erosion and Sediment Control Ordinance. This acceptance is based upon the following condition:

1. Silt and/or sediment shall not be allowed to leave the project site, including tracking onto public streets. Erosion and sediment controls, outlined in the accepted Erosion & Sediment Control Plan, shall be implemented and maintained to ensure this purpose. If silt, sediment, and/or dust are found to be leaving the site, the Owner (or their contractor) shall take immediate actions to correct the situation.
2. One set of the Final Erosion and Sediment Control Plan must be on-site at all times during construction and site stabilization.
3. Owner/Contractor shall not disturb greater than 5 acres at one time without seeking additional authorization to do so.

If you have any questions or comments regarding this letter, please do not hesitate to contact me. Furthermore, I would be happy to meet to discuss this subject in greater detail.

Sincerely,

Jessica Verrigni, CPESC, CPSWQ

Cc: Jimmie Joe Carl, Chemung County Stormwater
Tim Steed, Hunt Engineers
Aaron Vergason, Hunt Engineers
John Updyke, Owner