

Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control

Updated
const
list

Project Name	Hickory View Apartments	Date	9/3/13
Location	Hickory Grove Rd	Permit #	NYR10V597
Weather Conditions	overcast	Entry Time	10:24
On-Site Representative Present	Pete Diagoni Randy - Elm Structures	Exit Time	11:04

Sketch of Project site Include Disturbed Areas:

last insp. 7/10/13 - Marginal

Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
			All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
X			Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
X			Are the inspections being performed by a qualified individual?

Comments: It appears the contractor is finalizing everything on site.

- VOS next to future Bldg 12 needs to be re-done.

- Bldg 12 pad not growing grass

- Stockpile will need to be stabilized

- Large pond is being drained for final silt removal and

Satisfactory Marginal Unsatisfactory

Date	9/3/13	Inspector	Jessica Verrengni
------	--------	-----------	-------------------

vegetation.



851 Chemung Street
Horseheads, New York 14845
Ph. 607.796.2216

PROJECT: Hickory View Apartments
Town of Big Flats
September 3, 2013
Municipal Construction Insp.

BY Jessica Verrigni, CPESC, CPSWQ



VOS F4 holds water and is not establishing vegetation easily.



Vegetation is growing in well.



VOS K



Back pond being pumped down.



851 Chemung Street
Horseheads, New York 14845
Ph. 607.796.2216

PROJECT: Hickory View Apartments
Town of Big Flats
September 3, 2013
Municipal Construction Insp.

BY Jessica Verrigni, CPESC, CPSWQ



VOS L needs to establish more vegetation.



Contractor yard is getting cleaned up. The soil stockpile is being graded for final stabilization.



VOS E2 is holding water.



VOS E1 has not been re-worked yet.



851 Chemung Street
Horseheads, New York 14845
Ph. 607.796.2216

PROJECT: Hickory View Apartments
Town of Big Flats
September 3, 2013
Municipal Construction Insp.

BY Jessica Verrigni, CPESC, CPSWQ



VOS F1



VOS BCD has been re-shaped and graded. It now looks to be 2 feet deep and no water left the site in the last storm.



Pond 1.

