



VILLAGE OF HORSEHEADS

202 SOUTH MAIN STREET
HORSEHEADS, NY 14845

CLERK'S OFFICE (607) 739-5691
VILLAGE MANAGER (607) 739-5666
FAX (607) 739-3941
www.horseheads.org

Trustees Ronald R. Swartz
George F. Koliwasky
Mike Skroskznik
Brad S. Lytle

Mayor Donald W. Zeigler
Attorney John G. Groff
Clerk-Treasurer Sharron Cunningham
Manager Walter J. Herbst

September 9, 2015

Westco Corning, LLC
Jada Leo
200 Randolph Ave.
Huntsville, AL 35801

RE: FedEx Ground Distribution Center Village of Horseheads
SPDES Permit #NYR10Z781

Dear Jada Leo,

We have received Fagan Engineers request, dated September 1, 2015, to disturb greater than 5 acres of soil at any one time on the above referenced construction project. Based upon the information contained in the letter and the additional information submitted, your request to disturb greater than 5 acres has been approved. Work must be done as described in your letter and comply with the following conditions as per Local Law # 2 of 2008 and Part II.C.3 of GP-0-15-002:

1. All erosion and sediment control features must be properly maintained during construction.
2. The *owner or operator* shall have a *qualified inspector* conduct at least two (2) site inspections in accordance with the Permit every seven (7) calendar days for so long as greater than five (5) acres of soil remain disturbed and allow two (2) calendar days between inspections.
3. In areas where soil disturbance activity has been temporarily or permanently ceased, temporary and/or permanent soil stabilization measures shall be installed and/or implemented within seven (7) days from the date the soil disturbance activity ceased. The soil stabilization measures selected shall be in conformance with the most current version of the *New York State Standards and Specifications for Erosion and Sediment Control*.
4. The *owner or operator* shall install any additional measures needed to protect water quality.
5. Establish SWPPP communication track to be followed among permittee, inspector, contractor, municipality, and this office to secure prompt (within 48 hours) corrections to site deficiencies identified by each inspection.
6. The owner or operator includes the requirement above in their SWPPP (may be incorporated by inclusion of this document in site log book).

Should you have any questions regarding this letter or the requirements of our local law, please contact either myself or the Chemung County Stormwater Coalition.

Sincerely,

Robert Young
Code Enforcement/Stormwater Management Officer

Cc: K.Schwesinger, Fagan Engineers
Chemung County Stormwater Coalition