

Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control

Project Name Biltmore Crossing Apartments		Date 10/8/14	
Location Biltmore Drive Town of Horseheads		Permit # NYR10X559	
Weather Conditions sunny		Entry Time: 10:19am	
On-Site Representative Present: Chip Halsey-conifer		Exit Time:	
Construction Site Notes:			
-Rain overnight			
-NYSEG on site.			
Yes	No	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All erosion and sediment control measures installed/constructed
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	All erosion and sediment control measures maintained properly
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Are there currently more than 5 acres disturbed w/o prior approval
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Have stabilization measures been initiated in inactive areas
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Are permanent stormwater control measures being implemented
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Was there a discharge into the receiving water on the day of inspection
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Evidence of turbidity or oil in the receiving waters
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Are weekly inspections being performed?
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Are the inspections being performed by a qualified individual?
Corrections Needed:			
-Mud tracked onto Biltmore Dr. from both construction entrances. Maintenance required on both.			
-Check dams in swales still not right.			
-stabilization is needed in all areas sitting idle.			
-NYSEG is done on corner of Gardner and Biltmore- re-install silt fence.			
- Pollution prevention plan needs to be followed. Ie- trash and debris all over			
Satisfactory		Marginal	Unsatisfactory <input checked="" type="checkbox"/>
Date 10/8/14	Inspector Jessica Verrigni		

Unsatisfactory because items noted at last insp. still not corrected.



851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

PROJECT: Biltmore Crossing Apts.  
Biltmore Dr.- Horseheads (T)  
Municipal Inspection  
October 8, 2014

BY Jessica Verrigni, CPESC, CPSWQ



Construction Entrances- Both require maintenance and Gardner Road needs to be cleaned up.



Silt fence, that NYSEG replaced, needs to be replaced.



Stormwater pond is being utilized as a sediment trap.



Erosion is occurring on side slopes and check dams are not functioning.





CHEMUNG  
COUNTY  
STORMWATER  
COALITION

851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

PROJECT:	Biltmore Crossing Apts.
	Biltmore Dr.- Horseheads (T)
	Municipal Inspection
	October 8, 2014

BY	Jessica Verrigni, CPESC, CPSWQ
----	--------------------------------



Building materials are in the drainage swale and the check dam is not constructed correctly.



Mud tracked onto Gardner Road needs to be cleaned up daily.



Trash and debris needs to be cleaned up as part of the pollution prevention plan.

