



851 Chemung Street
Horseheads, New York 14845
Ph. 607.796.2216

PROJECT:	Red Robin
	Town of Horseheads
	Municipal Inspection
	September 18, 2014

BY	Jessica Verrigni, CPESC, CPSWQ
-----------	--------------------------------



Sediment mixed with stormwater is flowing over concrete curbs into parking area. Soil does have hydro seed applied but minimal grass is growing.

Sediment mixed with stormwater is flowing over concrete curbs into parking area. Soil does have hydro seed applied but minimal grass is growing.



Area covered in milled asphalt that needs to be brought back to original condition.



Trench open still.