

Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control

Project Name Red Robin			Date 11-3-14
Location Southern Tier Crossing Town of Horseheads			Permit # NYR10J873
Weather Conditions <i>partly cloudy-cool</i>			Entry Time: <i>11:51</i>
On-Site Representative Present: none			Exit Time: <i>12:03</i>
Construction Site Notes:			
-restaurant open. Waiting for final stabilization.			
Yes	No	N/A	
		X	All erosion and sediment control measures installed/constructed
		X	All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
X			Have stabilization measures been initiated in inactive areas
	X		Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
X			Are weekly inspections being performed?
X			Are the inspections being performed by a qualified individual?
Corrections Needed:			
- area between Mavis tire and red Robin has a drainage issue. I do not believe any of the soil was properly decomposed and that is one of the reasons grass is struggling to grow.			
- litter and debris is all over property			
Satisfactory			
Marginal <input checked="" type="checkbox"/>			
Unsatisfactory			
Date <i>11/3/14</i>		Inspector <i>Josuea Verrugini</i>	



851 Chemung Street  
Horseheads, New York 14845  
Ph. 607.796.2216

<b>PROJECT:</b>	Red Robin
	Town of Horseheads
	Municipal Inspection
	November 3, 2014

<b>BY</b>	Jessica Verrigni, CPESC, CPSWQ
-----------	--------------------------------



Vegetation is starting to establish itself.



Area where asphalt millings were placed and have not been removed.



Area where grass is not growing.



Area where grass is struggling to establish.